

HVAC Instant Rebate Program

Eligible Measures and Incentives 2023

(Effective July 1, 2023)

ELECTRIC | SEER | Residential HVAC and Water Heater Equipment

Measure Description	Minimum Efficiency Requirements*	Instant Rebate
Central air conditioning – Tier 1	SEER ≥ 16, EER ≥ 12.5	\$210
Central air conditioning – Tier 2	SEER ≥ 18, EER ≥ 13	\$300
Air-source heat pump – Tier 1	SEER ≥ 16, EER ≥ 12.5, HSPF ≥ 9	\$450
Air-source heat pump – Tier 2	SEER ≥ 18, EER ≥ 13, HSPF ≥ 10	\$600
Air-source heat pump – Cold climate – Tier 1	SEER ≥ 16, EER ≥ 12.5, HSPF ≥ 9, and COP ≥ 1.75 at 5°F	\$600
Air-source heat pump – Cold climate – Tier 2	SEER ≥ 18, EER ≥ 13, HSPF ≥ 10, and COP ≥ 1.75 at 5°F	\$600
Ductless mini-split heat pump	Single: SEER ≥ 20, EER ≥ 12.5, HSPF ≥ 10 Multi: SEER ≥ 18, EER ≥ 12.5, HSPF ≥ 10	\$240
Ductless mini-split air conditioning	SEER ≥ 20, EER ≥ 12.5	\$300
Heat pump water heater	ENERGY STAR® certified	\$600
Furnace fan	ECM motor install – Retrofit only	\$60
Smart thermostat	ENERGY STAR certified. New installation or replacement of a manual or conventional programmable thermostat, as part of an HVAC install.	\$60

ELECTRIC | SEER2 | Residential HVAC and Water Heater Equipment

Measure Description	Minimum Efficiency Requirements*	Instant Rebate
Central air conditioning split system – Tier 1	SEER2 ≥ 15.2, EER2 ≥ 12	\$210
Central air conditioning split system – Tier 2	SEER2 ≥ 16, EER2 ≥ 12	\$300
Central air conditioning single package – Tier 1	SEER2 ≥ 15.2, EER2 ≥ 11.5	\$210
Central air conditioning single package – Tier 2	SEER2 ≥ 17.1, EER2 ≥ 11.5	\$300
Air-source heat pump split system – Tier 1	SEER2 ≥ 15.2, EER2 ≥ 11.7, HSPF2 ≥ 7.8	\$450
Air-source heat pump split system – Tier 2	SEER2 ≥ 17.1, EER2 ≥ 11.7, HSPF2 ≥ 7.8	\$600
Air-source heat pump single package – Tier 1	SEER2 ≥ 15.2, EER2 ≥ 10.6, HSPF2 ≥ 7.2	\$450
Air-source heat pump single package – Tier 2	SEER2 ≥ 17.1, EER2 ≥ 10.6, HSPF2 ≥ 7.2	\$600
Air-source heat pump – Cold climate, ducted	SEER2 ≥ 15.2, EER2 ≥ 10, HSPF2 ≥ 8.1, COP ≥ 1.75 at 5°F and provide 70% capacity maintenance at 5°F	\$600
Ductless mini-split heat pump	Single: SEER2 ≥ 20, EER2 ≥ 12, HSPF2 ≥ 9 Multi: SEER2 ≥ 18, EER2 ≥ 12, HSPF2 ≥ 9	\$240
Ductless mini-split air conditioning	SEER2 ≥ 20, EER2 ≥ 12.5	\$300
Heat pump water heater	ENERGY STAR certified	\$600
Furnace fan	ECM motor install – Retrofit only	\$60
Smart thermostat	ENERGY STAR certified. New installation or replacement of a manual or conventional programmable thermostat, as part of an HVAC install.	\$60

GAS | Residential HVAC and Water Heater Equipment

Measure Description	Minimum Efficiency Requirements*	Instant Rebate
Reset controls for boiler	Attached to qualifying boiler	\$120
Gas boiler – Tier 1	AFUE 90%–94.99%	\$450
Gas boiler – Tier 2	AFUE ≥ 95%	\$510
Gas furnace – Tier 1	AFUE ≥ 95%–96.9%	\$390
Gas furnace – Tier 2	AFUE ≥ 97%	\$450
Gas combi heat – Tier 1	AFUE ≥ 95%	\$780
Gas combi heat – Tier 2	AFUE ≥ 97%	\$1,050
Gas storage tank water heater – Tier 1	Power-vented < 55 gallons, UEF ≥ 0.64 medium draw pattern, high draw pattern UEF ≥ 0.68	\$300
Gas storage tank water heater – Tier 2	Power-vented ≥ 55 gallons, UEF ≥ 0.78 medium draw pattern, high draw pattern UEF ≥ 0.80	\$450
Tankless water heater	UEF ≥ 0.87	\$450
Indirect fired storage tank water heater	When paired with qualifying gas boiler	\$150
Qualifying gas heater with qualifying gas water heater – Tier 1	< 55 gallons and UEF ≥ 0.64 medium draw pattern, UEF ≥ 0.68 high draw pattern or high capacity	\$660
Qualifying gas heater with qualifying gas water heater – Tier 2	≥ 55 gallons and UEF ≥ 0.78 medium draw pattern, UEF ≥ 0.80 high draw pattern or high capacity	\$780
Smart thermostat	ENERGY STAR certified. New installation or replacement of a manual or conventional programmable thermostat, as part of an HVAC install.	\$60

* SEER is seasonal energy efficiency ratio. EER is energy efficiency ratio. HSPF is heating season performance factor. SEER, EER, and HSPF ratings are determined by entering the model number of the indoor coil, the outdoor unit, and, in many cases, the air handler/furnace, into the AHRI directory (ahridirectory.org). UEF is uniform energy factor.